



NOTES:

1. FOR LEGEND, ABBREVIATIONS, AND GENERAL NOTES, SEE DWG. E-1. FOR INSTALLATION DETAILS, SEE DWG. E-2. FOR WIRING DIAGRAMS, SEE DWG. E-3 AND DWG. E-4.
2. REPLACE EXIST. STROBE (IF DIFFERENT) WITH THE SHOWN CANDELA RATED STROBE AND WIRE AS SHOWN. (EXIST. BACKBOX AND COND. STUB CAN BE UTILIZED IF IT IS SIMILAR TO THE TYPICAL FLUSH MOUNTED STROBE, SPEAKER, OR COMBINATION INSTALLATION DETAIL "B" ON DWG. E-2.
3. ONLY AFTER INSTALLED STROBES ARE TESTED AND OPERATIONAL, SHALL CONTRACTOR REMOVE EXISTING STROBE IN THE PRESENCE OF THE ENGINEER. FOR PAINTED DRY WALL, REMOVE EXISTING STROBE, BACK BOX AND PATCH TO MATCH EXISTING WALL FINISH.
4. SINCE FIRE ALARM CIRCUIT LENGTH IS CRITICAL, ROUTING AND INSTALLATION OF ALL FIRE ALARM CIRCUITS SHALL BE AS SHOWN ON DRAWING. ANY DEVIATION SHALL BE APPROVED BY THE ENGINEER, PRIOR TO INSTALLATION.
5. DISCONNECT AND ABANDON EXISTING STROBE CIRCUITS IN CEILING. TAPE ENDS OF ABANDONED CONDUCTORS AND TAG AS ABANDONED. THE WORK SHALL BE DONE IN THE PRESENCE OF THE ENGINEER.

THE PORT AUTHORITY
OF NY & NJ

[Signature]
ENGINEERING PROGRAM MANAGER
WORLD TRADE CENTER
CHIEF ELECTRICAL ENGINEER

No. Date Revision Approved

ENGINEERING DEPARTMENT

**WORLD
TRADE
CENTER**

ELECTRICAL

Title
**FIRE ALARM SYSTEM
DEVICE UPGRADE
PHASE III
5 WTC 3rd, 4th, 5th & 6th FLOORS**

**5th FLOOR
STROBE LAYOUT
INSTALLATION
AND REMOVAL
EAST PART PLAN**

This drawing subject to conditions in Contract. All inventions, ideas, designs and methods herein are reserved to Port Authority and may not be used without its written consent.

FELDSSTEIN APOSTLE A.S.
Designed by Drawn by Checked by

NOVEMBER 26, 1999
Date

WTC-861.573 E-05-4E
Contract Number Drawing Number

I HEREBY CERTIFY THAT THIS IS A TRUE AND CORRECT COPY OF ONE OF THE CONTRACT DRAWINGS CONSTITUTING A PART OF CONTRACT NO. **WTC-861.573** IN THE FORM IN WHICH SAID DRAWINGS EXISTED AT THE TIME THE SAID CONTRACT WAS EXECUTED BY THE PARTIES
DATE *2/1/00* *[Signature]*
DATE *2/14/00* *[Signature]*

